

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0065:159 Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Faraday Inc., 805 S. Maumee Street, Tecumseh, MI 49286
Contact: Steve Blohm (517) 423-2111

DESIGN: Models 8854 and 8843 photoelectric type smoke detectors. Model 8854 also have a supplemental 135°F heat sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-27 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as photoelectric type smoke detectors for use with listee's separately listed base Model 8853 (CSFM Listing No. 7300-0065:158)* and separately listed compatible fire alarm control units.

XLF: 7272-0067:186

*Corrected 09-22-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager